



Scan for User Manual

1 Product Introduction

M3-40-Dual is a three-phase meter designed for electricity monitoring and power metering in PV system, energy storage plants and more. It supports two channels so that you can monitor up to 2 power generation equipment at the same time.





Figure 1-1 M3-40-Dual appearance

Table 1-1 Description of meter appearance

No.	Type	Marking	Definition
A	Terminal	L1, L2 and L3	UL terminal, connected to the L wires of the grid
		N	UN terminal, connected to the N wire of the grid
B	Terminal	CT1 BLACK	Current input terminals, connected to the batch of CTs
		CT2 GREEN	
C	Terminal	A/A2	RS485 terminal A
		B/B2	RS485 terminal B
D	Indicator	A1-PIN4/A2-PIN4	RJ45 PIN4: RS485 terminal A
		B1-PIN5/B2-PIN5	RJ45 PIN5: RS485 terminal B
E	Function button	L1	Pulse indicators, flashes when the meter is working normally
		L2	
E	Function button	Fn	Function indicator, flashes when the meter phase sequence is being adjusted
		SET	<ul style="list-style-type: none"> Enter the parameter setting interface Confirm the selection Shift the cursor (when inputting digits)
		ESC	Exit from the current interface
		→	<ul style="list-style-type: none"> Go to the next item Increase the value
		←	<ul style="list-style-type: none"> Go to the next item Decrease the value

2 Scope of Delivery



3 Typical Networking Diagrams

The following diagrams use European TN-S for example, and are for reference only.




Figure 3-1 Networking through RS485 cable

The meter can also work with Wi-BR to transmit data within up to 200 m horizontally and 20 m vertically*.
















Figure 3-2 Wireless data transmission through Wi-BR

Note: The transmission data of Wi-BR comes from test results conducted in SolaX laboratories.

4 Compatible Inverters and Pin Definition

NOTICE				
For single-phase inverters, make sure to connect the voltage output cables to L1 and N wire terminal.				
Single Phase Inverter Models				
Table 4-1 SolaX inverter models and pin definition (1)				
Inverter series	Terminal type	Connector type	Pin No.	Pin definition
X1-HYB LV		RJ45	4	485A
			5	485B
X1-AC		RJ45	7	485A
			8	485B
<ul style="list-style-type: none"> X1-HYB G4 X1-FIT G4 X1-IES X1-VAST 		RJ45	4	485A
			5	485B
<ul style="list-style-type: none"> X1-MINI G4 X1-BOOST G4 		RJ45	4	485A
			5	485B
X1-SMART G2		Quick-connect terminal	4 / 11 5 / 12	485A 485B
*Note: Two pairs of terminals are available for meter connection on X1-Smart G2, and the pins in the same box are a pair.				
Three Phase Inverter Models				
Table 4-2 SolaX inverter models and pin definition (2)				
Inverter series	Terminal Type	Connector type	Pin No.	Pin definition
<ul style="list-style-type: none"> X3-HYB G4 X3-FIT G4 X3-IES X3-HYB G4 PRO 		RJ45	4	485A
			5	485B
X3-ULTRA		RJ45	4	485A
			5	485B
X3-MIC G2		RJ45	4	485A
			5	485B

Inverter series	Terminal Type	Connector type	Pin No.	Pin definition
X3-PRO G2		O/I terminal	5	485A
			6	485B
<ul style="list-style-type: none"> X3-MEGA G2 X3-FORTH 		Quick-connect terminal	7	485A
			8	485B
X3-AELIO		RJ45	4	485A
X3-HYB G4 PRO		RJ45	4	485A
			5	485B
			5	485B

5 Cable Requirements

Table 5-1 Required cables and specification					
Usage	Terminal marking	Cable type (Recommended)	Sectional area (mm ²)	Outer diameter (mm)	Prepared by
Voltage cable	L1, L2, L3 N	Multi-core outdoor copper wire	1.5~2.5	3~5	User
CT cable	8~1 Grid → Load	/	/	/	Supplier
COM cable	RS485A	Two-core outdoor shielded twisted pair cable	0.25~1.5	4~11	Supplier
	RS485B				
	RJ45	CAT6	/	/	

6 Electrical Connection

Power Cable Connection




Figure 6-1 Connecting power cables

CT Connection




Figure 6-2 Connecting CT cables

Communication Cable Connection

Select either terminal to connect communication cable for the meter.





Figure 6-3 Connecting communication cables

7 Installation



8 Technical Data

Table 8-1 Specification	
Power grid type	3P3W/3P4W
Rated voltage	3*57.7/100V...3*240/415V
Operating voltage	50 V~480 V
Current	*A/40 mA
Recommended CT specification	100 A/40 mA; 200 A/40 mA; 400 A/40 mA; 600 A/40 mA; 1000 A/40 mA;
Power consumption	<1.2 W
Measurement accuracy class	Voltage and current: Class 0.5 Active power: Class 1 Reactive power: Class 2
Resolution requirement	Active power: 0.1 W Frequency: 0.001 Hz
Frequency	45 Hz~65 Hz
Frequency tolerance	0.01 Hz
Operating temperature	-40°C to +70°C
Operating humidity	≤95%, non-condensing
Operating altitude	<4000 m
Degree of protection	IP20
Dimensions (W × H × D)	72 mm × 100 mm × 65.5 mm